



AIR FILTER CHECKS

- ISO 16890 Certified - ePM1 60%
- Eurovent Energy rating Certificate
- Pressure Drop Reading
- Seals and Gaskets present
- Filter Frame in good condition
- Filter construction still intact



SYSTEM CHECKS

- Ducts clean (No water build up)
- Supply air grids clean
- Supply/recirculation air ratio
- Fan belts aligned
- Fan operational



PUBLIC AND COMMERCIAL BUILDINGS CHECK

- Particle levels monitoring
- Microbiological monitoring