



## AIR FILTER CHECKS

- ISO 16890 Certified - ePM1 60%
- Prefilters meet ASHRAE 52.2 App. J
- HEPA filters IEST-RP-CC034 certified
- Pressure drop reading
- Seals and gaskets present
- Filter frame in good condition
- Filter construction still intact



## SYSTEM CHECKS

- Ducts clean (no water buildup)
- Supply air grilles clean
- Supply/recirculation air balanced
- Fan belts aligned
- Fan operational



## PUBLIC AND COMMERCIAL BUILDINGS CHECK

- Particle levels monitoring
- Microbiological monitoring